

2016 Annual Drinking Water Quality Report

Consumer Confidence Report (CCR)

PWS ID Number: **TX1940002**
PWS Name: **CITY OF CLARKSVILLE**

The source of drinking water used by
CITY OF CLARKSVILLE is Surface Water & Well Water, Langford Lake & Blossom Aquifer.

Annual Water Quality Report for the period of
January 1 to December 31, 2016.

This report is intended to provide you with
important information about your drinking water
and the efforts made by the water system to provide
safe drinking water.

Drinking water, including bottled water, may
reasonably be expected to contain at least small
amounts of some contaminants. The presence of
contaminants does not necessarily indicate that
water poses a health risk. More information about
contaminants and potential health effects can be
obtained by calling the EPAs Safe Drinking Water
Hotline at (800) 426-4791.

For more information regarding this report contact:

Name : DANIEL RAPIEN
Phone: 903-427-3834

Public Participation Opportunities

Date: 3rd Tuesday of each month
Time: 6:00 P.M.
Location: 800 W. Main Street
Clarksville, TX 75426
Phone Number: 903-427-3834

*To learn future public meetings (concerning your drinking water),
or to request to schedule one, please call us.*

Este informe contiene información muy importante
sobre el agua que usted bebe. Tradúzcalo ó hable
con alguien que lo entienda bien.

Special Notice

Required Language for ALL
Community Public Water Systems
Information on Sources of Water:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- ◇ Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ◇ Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- ◇ Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- ◇ Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- ◇ Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondary's are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

Information about Source Water Assessments

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidential Report. For more information on source water assessments and protection efforts at our system, contact Danial Rapien.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following link: <https://www.tceq.texas.gov/gis/swaview>
 Further details about sources and source-water assessments are available in Drinking Water Watch at the following link: <http://dww2.tceq.texas.gov/DWW/>

Source Water Name	Type of Water	Report Status	Location
1 –Raw Water Plant at Dam/LAKE LANGFORD	Surface Water	Y	100 E. LANGFORD LAKE ROAD
3 –Surface Water Treatment Plant	Ground Water	Y	1506 N. GRANT STREET
4 –1403 W. Washington/Vine	Ground Water	Y	1403 W. WASHINGTON STREET
5 –Comanche Street	Ground Water	Y	300 N. TRAVIS STREET

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Residual Disinfectant Level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residential Disinfectant Level Goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control contaminants.
NTU:	Nephelometric turbidity units (a measure of turbidity)
pCi/L	Picocuries per liter (a measure of radioactivity)
ppb:	Micrograms per liter or parts per billion—or on ounce in 7,350,000 gallons of water
ppm:	Milligrams per liter or parts per million—or one ounce in 7,350 gallons of water
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

DISINFECTANTS AND DISINFECTION BY-PRODUCTS	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2016	20	4.2-8.5	No goal for the Total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2016	64	20.4-163	No goal for the Total	80	ppb	N	By-product of drinking water disinfection.
INORGANIC CONTAMINANTS	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination.
Barium	2016	0.016	0.015–0.016	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2016	3	2.5-3	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	2016	0.6	0.632-0.632	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2016	0.0495	0.495-0.495	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2016	1.4	1.4-1.4	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
RADIOACTIVE CONTAMINANTS	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	5/27/2015	1.5	1.5-1.5	0	5	pCi/L	N	Erosion of natural deposits.

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Cooper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	8/20/2014	1.3	1.3	0.16	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
Lead	8/20/2014	0	15	3.6	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Turbidity

	Limit (Treatment Technique/TT)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.26 NTU	N	Soil runoff.
Lowest monthly % meeting limit	0.3 NTU	100%	N	Soil runoff.

Information on Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration

Maximum Residual Disinfectant Level

Systems must complete and submit disinfection data on the Surface Water Monthly Operations Report (SWMOR). On the CCR report, the system must provide disinfectant type, minimum, maximum and average levels.

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL MRDLG	Unit of Measure	Source of Chemical
2016	Disinfectant used	Average level of CCR year's quarterly	Minimum result single sample	Maximum result single sample	4.0 <4.0	ppm	Disinfectant used to control microbes
	Chlorine	1.14	0.52	2.66			